

# SDR 26 GASKETED

## Specifications

### SDR 26 Gasketed Fittings:

- Injection molded 4" to 12", fabricated 15" to 36".
- Manufactured in accordance with ASTM D-3034, ASTM F-1336 and CSA B182.2.
- Injection molded from virgin PVC compound having a cell classification of 12454 or 13343 in accordance with, and certified by the NSF to meet ASTM D-1784.
- Gaskets manufactured in accordance with ASTM F-477 or ASTM F-913.
- Gasket joints comply with ASTM D-3212 Internal Pressure Test (ex-filtration) and Vacuum Test (infiltration) with gasketed joint misalignment and 5% top load deflection.
- Gaskets shall be firmly seated in fitting in order to ensure proper installation and to prevent dislocation or misalignment during system assembly.
- Third party tested, certified and listed by NSF to meet specifications defined in ASTM D-3034, ASTM F-1336 and CSA B182.2, where applicable.



Injection molded from 4" to 12".  
Fabricated from 15" to 36".

### SDR 35 Gasketed Information

---

DO NOT USE FITTINGS FOR COMPRESSED AIR OR GASES.

---

DO NOT TEST PVC PIPING SYSTEMS WITH COMPRESSED AIR OR GASES.

---

DO NOT USE FITTINGS WITH LIQUIDS NOT RECOMMENDED BY TIGRE.

---

MODIFICATION OF FITTINGS VOIDS THE WARRANTY.

---

SPECS SUBJECT TO CHANGE WITHOUT NOTICE

---

*NSF Certified*



**TIGRE USA Inc.**  
2315, Beloit Avenue  
Janesville, WI 53546

customerservice@tigre.com  
www.tigreusa.com  
1.877.751.5371

© 05/2023